



GLB Wall Mounted Charging Station with DC Monitoring.

Type
GLBDC-T222FC


Fixed Cable
5 Meter cable
Rated current [A]
6,10,16,20,25,32
Power outlet [kW]
3.7KW,7.4KW,22KW
Load Balance
Available with
GNM3D-RS485

Meter
No.
Communication
Wifi Module Optional

RCCB/RCBO
No
DC Monitoring
Yes Built in.

RFID
RFID Module
Optional

Common characteristics
Rated voltage [V AC]
230/400
Frequency [Hz]
50
Temperature range [C]
-25...+40
Location
Wall mounted or GLB Stand.
Charge Current (A)
6,10,16,20,25,32,
Degree of protection [IP]
44
Standard
EN 61851-1 IEC 61439-7 AEVCS
Width [mm]
205
Height [mm]
422
Depth [mm]
124
Netweight [kg]
3.20
Materials
Plastic
Colour
Black





Dokument/document Försäkran om överensstämmelse/ Declaration of conformity		Utgåva datum/edition date 2015-05-04
Avdelning/department Kvalitet/Quality		
Ansvarig/prepared Kent Andersson	Version 4	Sida/page 1 av/of 1

Manufacturer/Tillverkare: GARO AB
Box 203
S-335 25 GNOSJÖ
Sweden

Telephone: +46 (0)370 33 28 00
Telefax: +46 (0)370 33 28 50

Agent established within EC/Ombud etablerad inom EG

Telephone:
Telefax:

Agent of equipment/Materielslag: Home charger/Hemmaladdare

Trade Mark/Varumärke: GARO

Type Designation/Typbeteckning: GHL-...GLB-...and/och GHLM-...

**We hereby declare that our product fulfils the requirements of following EC directives/
Vi intygar härmed att vår produkt uppfyller krav enligt följande EU direktiv:**

- The Low Voltage Directive (LVD) 2014/35/EU / Lågspänningsdirektivet (LVD) 2014/35/EU.**
- Electromagnetic compatibility (EMC) 2014/30/EU / Elektromagnetisk kompatibilitet (EMC) 2014/30/EU.**
- RoHS Directive (RoHS) 2011/65/EU / RoHS direktivet (RoHS) 2011/65/EU.**
- No electromagnetic compatibility (EMC 2014/30/EU) immunity or emission tests are required on the assembly / Produkten innehåller inte elektroniska apparater som påverkas enligt förbehållen enligt direktivet (EMC) 2014/30/EU.**

**The following harmonised standards (latest edition) or technical specifications which comply with good engineering practice in safety matters in force within the EC have been used in the design:/
Följande harmoniserade standarder (senaste utgåva) eller tekniska specifikationer som uppfyller god säkerhetsteknik praxis inom EG har använts i konstruktionen: EN 61851-1, EN 62196-2 and/och IEC/TS 61439-7.**

- The equipment confirms completely with the above stated harmonised standards or technical specifications./
Materielen överensstämmer helt med ovan angivna harmoniserade standarder eller tekniska specifikationer.**

Or/Eller

- The equipment confirms only partially with the above stated harmonised standards or technical specifications but complies with good practice in safety matters in force within the EC./
Materielen överensstämmer endast delvis med ovan angivna harmoniserade standarder eller tekniska specifikationer, men uppfyller god säkerhetsteknisk praxis inom EG.**

We have product surveillance according to CENELEC's harmonised requirements, documents CCA-201.

GARO AB
Company/Företag

2017-11-24
Date/Datum

Sign/Underskrift

Responsible for Technology and standardization/Teknik och standardiseringsansvarig
Position/Befattning

Kent Andersson
Sign in printed letters/Namnförtydligande